



Republic of the Philippines
Department of Education
REGION I
SCHOOLS DIVISION OF VIGAN CITY

15 JUN 2026

DIVISION MEMORANDUM

No. 438, s. 2026

RESULTS OF THE SCHOOL BUILDING INSPECTION

TO: Assistant Schools Division Superintendent
Chief Education Supervisors
Public Elementary and Secondary School Heads
All Others Concerned

1. Relative to the conduct of fire safety and building inspections by the Bureau of Fire Protection Vigan City in public schools within the division as part of the Brigada Eskwela and school safety initiatives, this Office hereby informs all concerned schools of the inspection results issued by the inspection team.
2. The inspection identified areas requiring corrective actions to ensure compliance with fire safety standards, building safety requirements, and the provision of a safe learning environment for learners, teaching, and non-teaching personnel.
3. In view thereof, all School Heads are directed to immediately review findings and undertake the necessary corrective measures.
4. The cooperation of all schools in addressing the identified findings is essential in promoting safe, resilient, and disaster-ready learning environment.
5. Attached is the summary of school-specific findings from the Bureau of Fire Protection Vigan City.
6. For information and compliance of all concerned.

VILMA D. EDA, CESO V
Schools Division Superintendent

SCHOOLS DIVISION OFFICE
DEPED VIGAN CITY
15 JUN 2026
RELEASED
BY: *[Signature]*

SGOD/DRRM/rqg
June 15, 2026



Address: Mena Crisologo St. corner Rivero St., Brgy. IX, Vigan City, Ilocos Sur
Telephone No: (077) 722-20-23 / (077) 632-05-33
Email Address: vigan.city@deped.gov.ph
Website: www.depedvigan.city

Your Feedback is important to us. Visit this link bit.ly/SDOViganCityCSM






2606-1057
SCHOOLS DIVISION OFFICE
DEPED VIGAN CITY
 10 JUN 2026
RECEIVED
 BY: 8/6/

Republic of the Philippines
 Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
VIGAN CITY FIRE STATION

Rivero St., Brgy VIII, Vigan City Ilocos Sur
 Tel. Number (077) 604-5142/Mobile Number 0917-1873911
 email: bfpvigansfinest@yahoo.com.ph

SCHOOL	DEFECTS/DEFICIENCIES
1. MINDORO ELEMENTARY SCHOOL	No defects and deficiencies
2. CABAROAN – CABALANGEGAN ELEMENTARY SCHOOL	1. Unserviceable fire extinguisher at Principal's office, Army type building and JICA building. 2. Absence of exit signs at Mario A. Albalos Library Uninstalled fire alarm bell.
3. BULALA – PARATONG ELEMENTARY SCHOOL	Defective fire alarm bell.
4. VIGAN NATIONAL HIGH SCHOOL EAST	1. Defective fire alarm bell / switch at admin building. 2. Defective convenience outlet at admin building. 3. Unserviceable fire extinguisher at admin building. 4. Hanging wires at library.
5. VIGAN CENTRAL SCHOOL	1. Absence of secondary exit window opening at grade 2 room (Industrial Arts Building), Marco pre-Fabricated School Building and Bayanihan Building. 2. Unserviceable fire extinguisher at Bagong Lipunan 2 building. Absence of fire extinguisher at Grade IV room (Gabaldon Building) and at Security Bank Foundation, INC building.
6. VIGAN NATIONAL HIGH SCHOOL WEST	1. Absence of secondary exit window opening at Grade 8 Jupiter. Unserviceable fire extinguisher at school canteen & Grade 9 Pearl.
7. JOSE SINGSON ELEMENTARY SCHOOL	No defects and deficiencies
8. PANTAY INTEGRATED SCHOOL	No defects and deficiencies
9. BURGOS MEMORIAL SCHOOL EAST	No defects and deficiencies
10. NAGSANGALAN ELEMENTARY SCHOOL	No defects and deficiencies
11. CAMANGAAN ELEMENTARY SCHOOL	No defects and deficiencies
12. ILOCOS SUR NATIONAL HIGH SCHOOL	No defects and deficiencies
13. RAOIS ELEMENTARY SCHOOL	No defects and deficiencies
14. CAPANGPANGAN Elementary School	Un-Serviceable Fire Extinguisher

15. RUGSUANAN-PUROC Elementary School	No Defects and Deficiencies
16. TAMAG ELEMENTARY SCHOOL	UNSERVICEABLE FIRE EXTINGUISHER
17. SALINDEG ELEMENTARY STORE	NO DEFECTS
18. GOV. EVARISTO SINGSON II MEMORIAL ELEMENTARY SCHOOL	NO DEFECTS
19. BURGOS MERMORIAL SCHOOL WEST	NO DEFECTS
20. SAN JULIAN ELEMENTARY SCHOOL	NO DEFECTS
21. AYUSAN-PAOA ELEMENTARY SCHOOL	NO DEFECTS



SFO2 Rommel Amano
Chief Fire Safety Enforcement Section



CINS P RONALD N CASTILLO
Acting City Fire Marshal